

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. E/115

Dated: 21/6/25

It is certified that an inspection team headed by Harendra Kumar Yadav

(Name of Officers with designation) from U.P. Jal Nigam Etah PHED

inspected the ST. JOHN'S CHURCH SCHOOL, ETAH

(Name & Address of the school) on 19/6/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no..... dated 21-06-2025

of U.P. JAL NIGAM ETAH (PHED Lab) certified that the

ST. JOHN'S CHURCH SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 31-03-2026

Signature with Seal:

Name

Designation

Name & Address of the Office / Department U.P. J.N.

Etah

To ST. JOHN'S CHURCH SCHOOL

KACHEHRI ROAD, ETAH 207001

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Office of Executive Engineer, Jal Nigam
(Gramin) Etah U.P.
Water Analysis Report

To,

Report No.E115

Place/Source of Sample - ST . John's Church School Kacheri Road Etah.
Village Name-Etah dehat Block-Seetalpur District- Etah
Name of Sample Collector- Nalini Thompkinnson Date/Time- 19/6/2025 9:58 am
Date of Analysis- 21-06-2025

S. No.	Parameter (Unit)	BIS Acceptable Limit	Unit Mg/l	BIS Permissible Limit in Absence of alternate source	Result	Remarks
1	Turbidity	1.0	NTU	5	0.99	
2	pH	6.5-8.5	-	No Relaxation	7.04	
3	Chloride	250	Mg/l	1000	78	
4	TDS	500	Mg/l	2000	488	
5	Alkalinity	200	Mg/l	600	68	
6	Fluoride	1	Mg/l	1.5	0.5	
7	Nitrate	45	Mg/l	No Relaxation	1.84	
8	Sulphate	200	Mg/l	400	54	
9	Total Hardness	200	Mg/l	600		
10	Iron	1	Mg/l	No Relaxation	0.01	
11	Calcium	75-200	Mg/l		68	
12	Magnesium	30-100	Mg/l		58	
13	Colour	5-15	Hazen Unit		5	
14	Odour	-	-		Agreeable	
15	Test	-	-		Agreeable	

Remark- The results reported above are as per the water sample supplied by client to the District Water Testing Laboratory,(Etah)U.P.

Authorised Signatory
U.P. Jal Nigam (Etah)